

**ADDENDUM NO. 1**

April 12, 2023

Air Quality Upgrades for Beltline and Northeast Campus  
State Project No. H59-N191-FW  
Midlands Technical College

Engineer's Commission No. 21-39

-----  
This addendum consists of one (1) typed page. The following changes and/or modifications to the Contract Documents are part thereof; and change the original documents only in the manner and extent stated below.  
-----

**EQUIPMENT MANUFACTURERS' PRIOR APPROVAL**

1. Plasma Air is an approved equal for the Air Purification (Needlepoint Bi-polar Ionizations) Devices.

Modify Sheet 8, OUTLINE SPECIFICATIONS, Note 10, Line 1 to read:

“GPS AIR MODELS ARE THE BASIS OF DESIGN FOR NEEDLEPOINT BI-POLAR IONIZATION DEVICES. OTHER MANUFACTURERS OF ACCEPTABLE EQUIPMENT INCLUDE iWAVE, BIOCLIMATIC, AND PLASMA AIR.”

2. Contractor and equipment supplier shall refer to Sheet M8, OUTLINE SPECIFICATIONS, Note 9 for information on equipment substitutions.

3. Contractor is reminded to acknowledge receipt of this Addendum No. 1 on the Bid Form. Failure to do so may constitute a reason to reject the quote.

**BIDDER SUBMISSIONS**

1. All bids are to be submitted via hand delivery or mail service to W. Carey Page at Reed Hall, 1260 Lexington Drive (Room 119), West Columbia, SC 29170, by 2:00 pm, April 20, 2023, per SE-310 Invitation for Design-Bid-Build Construction Services.

**END OF ADDENDUM NO. 1**